



Indoor-outdoor cooling potential of nature-based solutions

**An application to university
campus retrofit**

Agnese Salvati | UPC · Barcelona Tech

Carlos Lopez-Ordoñez | UPC · Barcelona Tech

Roser Capdevila | UPC · Barcelona Tech

Núria Garrido | UPC · Barcelona Tech

Introduction



EDUncational campuses as drivers for **P**ositive **E**nergy **D**istricts

- To **accelerate the transition** to Positive Energy Districts (**PEDs**) in urban areas.
- Applying **morphology approach** for **energy-positive regeneration and refurbishment**
- **Leveraging on educational institutions** with sizeable built assets in cities as the drivers, orchestrators, and knowledge hubs for upscaling PED Urban Living Labs.

Introduction



EDUncational campuses as drivers for **P**ositive **E**nergy **D**istricts

University Campuses as **Living Labs**

- **Reduce Energy** consumption
- Optimise **renewable energy generation** and flexibility
- Improve **climate adaptation**

Introduction



EDUncational campuses as drivers for **P**ositive **E**nergy **D**istricts

University Campuses as **Living Labs**

- **Reduce Energy** consumption
- Optimise renewable energy generation and flexibility
- Improve **climate adaptation**




Nature-Based Solutions (NBS)

Objective

To quantify **the global cooling potential of NBS** applied to building retrofits at the **building and the district scales**, considering their **dual impact on the indoor and outdoor thermal environment**.

Nature-Based Solutions

Scale of application




Case study: UPC campus and district in Terrassa


Building
Library



District



Methodology



Outputs

NBS scenarios :

- Green Façades (GF)
- Green Roofs (GR)

Scale of application:

- Building
- District

Meteorological data: Typical day of August
(based on the last 10 years data)

Simulation time: 42h

/ Atmosphere

Ambient temperature
Mean Radiant Temperature
Humidity
Wind speed

Outdoor

UHI
OTC

/ Biomet

PET Physiological Equivalent temperature


/ Buildings / Dynamic

Wall Surface temperatures
(OUTSIDE)

/ Atmosphere

Ambient temperature

Boundary conditions



Outputs

Indoor

Mean Radiant Temperature
Air temperature
Operative temperature
Cooling energy

THERMAL COMFORT
ENERGY


Methodology

Scenarios:

Library GF

District GF

District GF + GR



NBS :

Green Façade (GF)

Green Façade (GF)

Green Façade (GF) + Green Roof (GR)

Scale:

Building
100 % opaque wall

District
50% building facades

District
50% building facades
50 % Roof surface (flat roofs)

RESULTS

Outdoor

OUTDOOR THERMAL COMFORT (OTC)
URBAN HEAT ISLAND (UHI)


Indoor

INDOOR THERMAL COMFORT
COOLING ENERGY DEMAND


Outdoor Absolute difference Potential Air Temperature:

Typical August day | h19:00 | k=6=5m





Base Case - Library GF



Base Case - District GF




Base Case - District GF + GR




min 0.00 K | max 0.13 K

min 0.00 K | max 0.31 K


min -0.01 K | max 0.50 K






Base Case - Library GF




Base Case - District GF



Base Case - District GF + GR







Outdoor

Absolute difference **S**pecific **H**umidity:

Typical August day | **h**19:00 | **k**=3=1.40m





below 0.15 K

0.15 to 0.30 K

0.30 to 0.45 K

0.45 to 0.60 K

0.60 to 0.75 K

0.75 to 0.90 K

0.90 to 1.05 K

1.05 to 1.20 K

1.20 to 1.35 K

above 1.35 K

Point 02

Δ PET (°C)

6:00 8:00 10:00 12:00 14:00 16:00 18:00 20:00 22:00 0:00 2:00 4:00 6:00 8:00 10:00 12:00 14:00 16:00 18:00 20:00 22:00 0:00

Base Case

Point 02

Δ PET (°C)



6:00 8:00 10:00 12:00 14:00 16:00 18:00 20:00 22:00 0:00 2:00 4:00 6:00 8:00 10:00 12:00 14:00 16:00 18:00 20:00 22:00 0:00

Base Case - Library GF

Base Case - District GF


Base Case - District GF + GR

Building Wall: Temperature Nodes | **OUTSIDE**





Building Wall: Temperature Nodes | **OUTSIDE**



ENVI
_MET




Point 06





Point 07



Point 08



Building Temperature of Library | **INSIDE**



h 18:00

Base Case - Library GF (District GF) → -1.27 °C



h 18:00

Base Case - District GF + GR → -2.50 °C



"Other side coefficient" object used to feed the hourly wall surface temperature calculated by ENVImet as **boundary conditions for EnergyPlus calculation**

Wall: Temperature Nodes | **OUTSIDE**



Limitations of the "Other side coefficient" approach:



- It cannot be applied to windows
- **It cannot be applied to walls including windows**



"Other side coefficient" object used to set the hourly wall surface temperature calculated by ENVImet as **boundary conditions for EnrgyPlus calculation**

Mean Radiant Temperature | **INSIDE***

MRT





Base Case - Library GF → -0,4 °C (Max)

*Results for 1 Zone, with GF on the southern façade. The wall has 5cm thermal insulation



"Other side coefficient" object used to set the hourly wall surface temperature calculated by ENVImet as **boundary conditions for EnrgyPlus calculation**

Operative Temperature| **INSIDE***



Base Case - Library GF → -0,5 °C (Max)

*Results for 1 Zone, with GF on the southern façade. The wall has 5cm thermal insulation





"**Other side coefficient**" object used to set the hourly wall surface temperature calculated by ENVI-met as **boundary conditions for EnergyPlus calculation**

+

Morphed weather file, to include the beneficial effect of district-scale NBS applications on air temperature (UHI)

District Cooling | Buildings



-3% Distric cooling reduction

Conclusions

Outdoor

- District-scale applications of GF and GR can contribute to mitigate UHI. The maximum positive impact is up to 0,5 °C reduction in the evening.
- GF have positive impact on street-level thermal conditions, reducing MRT by up to 3,5 °C and PET by 2 °C.

Indoor

- The outside wall surface temperature is reduced by up to 20 °C, but the impact on indoor operative temperature is limited to 0,5 C*
- The UHI mitigation entails a small reduction in cooling energy for the library buildings by 3%

*Preliminary results



Future work

ENERGYPLUS-ENVImet : Complete the study and improve the coupling methodology

Urban microclimate simulations: Explore other models (Vertical City Weather Generator)

Nature- base solutions: Explore different systems (green walls)




Image source: Nicole Pfoer (2024), Green Facades. DETAIL PRACTICE.

Acknowledgments:

This work has been supported by the EDUPED project (PCI2024-155068-2), funded by the Spanish State Research Agency (AEI) under the 'International Collaboration Projects' initiative. Call: PCI2024-2"



Thank you!

Agnese.salvati@upc.edu